

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:26 pm

PWS ID: UTAH19014 **Name:** HOVENWEEP NM
Legal Contact: NPS - HOVENWEEP NM **Rating:** Approved
CORKY HAYS **Rating Date:** 04/09/1996
Address: HC 60 BOX 1 **Activity Status:** Active
LAKE POWELL, UT 84533
Phone Number: 435-692-1234
City Served (Area):
County: SAN JUAN COUNTY
System Type: Non-community **Last Inv Update:** 03/16/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 03/23/2010 **Total Dsgn Cap:**
Population: 25 **Surveyor:** MARK BERTELSON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	HAYS, CORKY	SUPERINTEND	435-692-1234		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	7
			7 Total Svc Connections

Storage

Total Storage: 40,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	40,000 GAL	Steel		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	1437 FT. WELL CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	1437 FT. WELL	Active	WL	8	50 GPM		Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.